

■ Features:

- ·Output constant Voltage
- ·Range: 100-265VAC
- ·Built-in active PFC function
- ·Efficiency up to 90%
- ·Protections: short circuit/over load/ over circuit/ over temperature ·Cooling by free air convection
- ·IP66 design for indoor and outdoor installation .
- •Dimming function: Built in DALI interface dimming function conform to DALI Protocol IEC62386
- ·Dimming range from 0.1% to 100%
- ·Suitable for intelligent LED lighting
- ·Compliance to worldwide safety regulations for lighting
- ·Suitable for dry locations

Specification

C € ⊕ ⊕ ቜ IP66 SELV

•	Model	KV-12150-DA	KV-24150-DA	
Output	DC Voltage	12V	24V	
	Voltage Tolerance	±0.5V		
	Rated current	0 - 12.5A	0 - 6.25A	
	Rated power	150W	150W	
Input	Voltage Range	100-265VAC		
	Frequency Range	47 - 63HZ		
	Power Factor	PF≥0.98/120VAC PF≥0.98/230VAC PF≥0.95/265VAC (Full loading)		
	Full Load Efficiency(Typ.)	89%	90%	
	AC Current(Max.)	1.49A	1.47A	
	Leakage current	<0.5mA		
Protection	Short Circuit	Protection type: Hiccup mode, recovers automatically after fault condition is removed.		
	Over Load	≤120%		
	Over Circuit	≤1.2*lout		
	Protection Class:	Ι		
	Over temperature	100 $^\circ\!\mathrm{C}\pm10^\circ\!\mathrm{C}$ shut down o/p voltage, re-power on to recover		
Environment	Working TEMP.	-40 - +60℃		
	Working Humidity	20 - 95%RH,non-condensing		
	Storage TEM.,Humidity	-40 - +80℃,10 - 95%RH		
	TEMP.coefficient	±0.03%/°C(0 - 50°C)		
	Vibration	10 - 500Hz, 5G 12min./1 cycle, period for 72min.each along X,Y,Z axes.		
Safety & EMC	Safety standards	EN61347-1 EN61347-2-13 IP66		
	Withstand voltage	I/P-O/P:3.75KVAC I/P-FG:1.88KVAC O/P-FG:0.5KVAC		
	Isolation resistance	I/P-O/P I/P-FG O/P-FG: 100MΩ/500VDC/25°C/70%RH		
	EMC Emission	EN55015,EN61000-3-2 (≥60%load)		
	EMC Immunity	EN61000-4-2,3,4,5,6 ,11,EN61547,A light industry level (surge4KV)		



	Weight	1.6Kg				
Others	Dimension	256*78*47mm (L*W*H)				
	packing	340*280*185mm/10pcs/CTN				
Notes	1. All parameters NOT	1. All parameters NOT specially mentioned are measured at 230VAC input , rated load and 25 $^\circ$ C of				
	ambient temperature	ambient temperature.				
	2. Tolerance: includes	2. Tolerance: includes set up tolerance, line regulation and load regulation .				
	3. The power supply is	3. The power supply is considered as a component that will be operated in combination with final				
	Equipment. Since El	Equipment. Since EMC performance will be affected by the complete installation, the final				
	equipment manufact	equipment manufactures must be-qualify EMC Directive on the complete installation again.				

256 244 238 Output ſ Input 78 43 -0 Dimming 8 5 200 47 200

Mechanical Specification

Label

• L Brown	LED Driver(DALI Dimm Constant Voltage Model:	ing) • tc		Red + Black -
	Input: Output:	100		Blue 5
Y/G ● N Blue	Ta:50°C Tc:90°C Building 3. No. 19, Yongtian Road, Qianshan Industrial 2	one. Zhuhal City, Guand	doog Province. China	White of

%Input Rubber cable H05RN-F 3G 1.0mm², the green/yellow cable connect with (FG), Brown with AC (L), Blue with AC(N)

%Signal Rubber cable H05RN-F 2*0.75mm²,Blue and White is DA1, DA2 (No polar). Connected to the BUS of the DALI Master.

※Output rubber cable :1 group of H05RN-F 2*1.5mm² for KV-24150-DA; 2 group of 2*1.5mm² for KV-12150-DA, Red is output (V+) Positive,Black is output (V-) negative. Connected to LED Lamps.

Please make sure you connect these correctly otherwise your product will not function correctly and could be damaged.

%Note: Any other requests we can customized.



Dimming Operation

Operation Reference No.1:



*Please refer to Diagram 1. Connect the Dali signal line to the Dali bus of the controller (the Dali Master). After Dali Master scanning and address assignment, the driver can be successfully dimmed.

*Notice:In the market, some DALI controllers has bus-powered functions .If not,please add an extra power supply.(DALI Power).

%Any incorrect connecting of signal line and output line would damage the master.

Operation Reference No.2:



DALI BUS

*Please refer to Diagram 2. Connect the Dali signal line to the Dali controller.



Operation Reference No.3:



%Please refer to Diagram 3 Connect the Dali signal line to the Dali dimmers.

Derating Curve



*To extend their life, please refer to the Derating Curve and derate according to the temperature.

Instruction:

1)This driver should be installed by qualified and professional person;

2)Please make sure the transformer is installed with adequate ventilation around it to allow for heat dissipation.3)Ensure that wiring is correct before test in order to avoid light and power supply damage;

4) If driver Cannot work normally, don't maintain privately; Have any question, please contact Shengchang.



Any other question please feel free to contact ZHUHAI SHENGCHANG ELECTRONICS CO., LTD